

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries
Street: 8501 NW 90th Street
City/State/Zip: Medley, FL 33166

Product Series: 4000/6000 Fixed
Product Type: FIXD
Air Leakage:
VR (Standard Screen):
VR (Enhanced Screen):

Simulation Lab: SFTL
Sim. Report #: 9054-1
Sim. Report Date: 07/21/2016

Initial Cert. Date: 05/16/2007
Re-Certification Date: 08/26/2016
Revised Date: 12/13/2017

Print Date: 08/09/2018

Test Date: 07/14/2016

Expiration Date: 07/14/2021

CPD Number: LAW-A-4

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00051-00001	1/8 Gray - Air - 1/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR (100)	N		GY	0.65	0.58	0.52	17
	00051-00002	1/8 Gray - Air - 1/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR (100)	N		GY	0.65	0.58	0.52	17
	00051-00003	1/8 Clear - Air - 1/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR (100)	N		CL	0.65	0.73	0.77	17
	00051-00004	1/8 Clear - Air - 1/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR (100)	N		CL	0.65	0.73	0.77	17
	00051-00005	1/8 Green - Air - 31/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR (100)	N		GR	0.65	0.58	0.70	17
	00051-00006	1/8 Green - Air - 31/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR (100)	N		GR	0.65	0.58	0.70	17
	00051-00007	1/8 Bronze - Air - 1/8 Clear	AL/N	2		0.250	A8-S	Fill 1: AIR (100)	N		BZ	0.65	0.59	0.57	17
	00051-00008	1/8 Bronze - Air - 1/8 Clear	AL/N	2		0.250	P1-S	Fill 1: AIR (100)	N		BZ	0.65	0.59	0.57	17
	00052-00001	1/8 Comfort E2 - Air - 1/8 Clear	AL/N	2	0.204(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.57	0.63	0.70	18
	00052-00002	1/8 Comfort E2 - Air - 1/8 Clear	AL/N	2	0.204(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.57	0.63	0.70	18
	00053-00001	1/8 Clear	AL/N	1			N		N		CL	1.08	0.82	0.84	12
	00053-00002	1/8 Green	AL/N	1			N		N		GR	1.08	0.67	0.77	12
	00053-00003	1/8 Bronze	AL/N	1			N		N		BZ	1.08	0.69	0.63	12
	00053-00004	1/8 Gray	AL/N	1			N		N		GY	1.08	0.67	0.58	12
	00053-00005	3/16 Clear	AL/N	1			N		N		CL	1.08	0.80	0.83	12
	00053-00006	3/16 Green	AL/N	1			N		N		GR	1.08	0.61	0.74	12
	00053-00007	3/16 Bronze	AL/N	1			N		N		BZ	1.08	0.62	0.54	12
	00053-00008	3/16 Gray	AL/N	1			N		N		GY	1.08	0.60	0.47	12
	00053-00009	1/4 Clear	AL/N	1			N		N		CL	1.08	0.78	0.83	12
	00053-00010	1/4 Green	AL/N	1			N		N		GR	1.08	0.59	0.72	12
	00053-00011	1/4 Bronze	AL/N	1			N		N		BZ	1.08	0.59	0.50	12
	00053-00012	1/4 Gray	AL/N	1			N		N		GY	1.08	0.57	0.42	12
	00054-00001	1/8 LoE 366 - Air - 1/8 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.28	0.60	17
	00054-00002	1/8 LoE 366 - Air - 1/8 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.28	0.60	17

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries
Street: 8501 NW 90th Street
City/State/Zip: Medley, FL 33166

Product Series: 4000/6000 Fixed
Product Type: FIXD
Air Leakage:
VR (Standard Screen):
VR (Enhanced Screen):

Simulation Lab: SFTL
Sim. Report #: 9054-1
Sim. Report Date: 07/21/2016

Initial Cert. Date: 05/16/2007
Re-Certification Date: 08/26/2016
Revised Date: 12/13/2017

Print Date: 08/09/2018

Test Date: 07/14/2016

Expiration Date: 07/14/2021

CPD Number: LAW-A-4

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Llys	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00054-00003	3/16 LoE 366 - Air - 3/16 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.28	0.59	17
	00054-00004	3/16 LoE 366 - Air - 3/16 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.28	0.59	17
	00055-00001	1/8 LoE 270 - Air - 1/8 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.37	0.65	17
	00055-00002	1/8 LoE 270 - Air - 1/8 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.37	0.65	17
	00055-00003	3/16 LoE 270 - Air - 3/16 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.36	0.64	17
	00055-00004	3/16 LoE 270 - Air - 3/16 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.36	0.64	17
	00056-00001	1/8 LoE 240 - Air - 1/8 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.27	0.37	17
	00056-00002	1/8 LoE 240 - Air - 1/8 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.27	0.37	17
	00056-00003	3/16 LoE 240 - Air - 3/16 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.27	0.36	17
	00056-00004	3/16 LoE 240 - Air - 3/16 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.27	0.36	17
	00057-00001	1/8 LoE 366 - Arg - 1/8 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.60	17
	00057-00002	1/8 LoE 366 - Arg - 1/8 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.60	17
	00057-00003	3/16 LoE 366 - Arg - 3/16 Clear	AL/N	2	0.022(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.59	17
	00057-00004	3/16 LoE 366 - Arg - 3/16 Clear	AL/N	2	0.022(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.59	17
	00058-00001	1/8 LoE 270 - Arg - 1/8 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.36	0.65	17
	00058-00002	1/8 LoE 270 - Arg - 1/8 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.36	0.65	17
	00058-00003	3/16 LoE 270 - Arg - 3/16 Clear	AL/N	2	0.037(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.36	0.64	17
	00058-00004	3/16 LoE 270 - Arg - 3/16 Clear	AL/N	2	0.037(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.36	0.64	17
	00059-00001	1/8 LoE 240- Arg - 1/8 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.47	0.26	0.37	17
	00059-00002	1/8 LoE 240- Arg - 1/8 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.47	0.26	0.37	17
	00059-00003	3/16 LoE 240 - Arg - 3/16 Clear	AL/N	2	0.057(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.47	0.26	0.36	17
	00059-00004	3/16 LoE 240 - Arg - 3/16 Clear	AL/N	2	0.057(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.47	0.26	0.36	17
	00060-00001	1/8 Comfort Select 28 - Air - 1/8 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.59	17
	00060-00002	1/8 Comfort Select 28 - Air - 1/8 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.59	17

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries
Street: 8501 NW 90th Street
City/State/Zip: Medley, FL 33166

Product Series: 4000/6000 Fixed
Product Type: FIXD
Air Leakage:
VR (Standard Screen):
VR (Enhanced Screen):

Simulation Lab: SFTL
Sim. Report #: 9054-1
Sim. Report Date: 07/21/2016

Initial Cert. Date: 05/16/2007
Re-Certification Date: 08/26/2016
Revised Date: 12/13/2017

Print Date: 08/09/2018

Test Date: 07/14/2016

Expiration Date: 07/14/2021

CPD Number: LAW-A-4

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00060-00003	3/16 Comfort Select 28 - Air - 3/16 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.58	17
	00060-00004	3/16 Comfort Select 28 - Air - 3/16 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.58	17
	00061-00001	1/8 Comfort Select 36 - Air - 1/8 Clear	AL/N	2	0.027(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.36	0.62	17
	00061-00002	1/8 Comfort Select 36 - Air - 1/8 Clear	AL/N	2	0.027(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.36	0.62	17
	00061-00003	3/16 Comfort Select 36 - Air - 3/16 Clear	AL/N	2	0.026(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.36	0.61	17
	00061-00004	3/16 Comfort Select 36 - Air - 3/16 Clear	AL/N	2	0.026(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.36	0.61	17
	00062-00001	1/8 Clima Guard 55/27 - Air - 1/8 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.52	17
	00062-00002	1/8 Clima Guard 55/27 - Air - 1/8 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.52	17
	00062-00003	3/16 Clima Guard 55/27 - Air - 3/16 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.51	17
	00062-00004	3/16 Clima Guard 55/27 - Air - 3/16 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.29	0.51	17
	00063-00001	1/8 Clima Guard 63/31 - Air - 1/8 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.31	0.58	17
	00063-00002	1/8 Clima Guard 63/31 - Air - 1/8 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.31	0.58	17
	00063-00003	3/16 Clima Guard 63/31 - Air - 3/16 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.31	0.58	17
	00063-00004	3/16 Clima Guard 63/31 - Air - 3/16 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.31	0.58	17
	00064-00001	1/8 Clima Guard 70/36 - Air - 1/8 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.34	0.59	17
	00064-00002	1/8 Clima Guard 70/36 - Air - 1/8 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.34	0.59	17
	00064-00003	3/16 Clima Guard 70/36 - Air - 3/16 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: AIR (100)	N		CL	0.53	0.32	0.56	17
	00064-00004	3/16 Clima Guard 70/36 - Air - 3/16 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: AIR (100)	N		CL	0.53	0.32	0.56	17
	00065-00001	1/8 Comfort Select 28 - Arg - 1/8 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.59	17
	00065-00002	1/8 Comfort Select 28 - Arg - 1/8 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.59	17
	00065-00003	3/16 Comfort Select 28 - Arg - 3/16 Clear	AL/N	2	0.021(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.29	0.58	17
	00065-00004	3/16 Comfort Select 28 - Arg - 3/16 Clear	AL/N	2	0.021(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.29	0.58	17

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries
Street: 8501 NW 90th Street
City/State/Zip: Medley, FL 33166

Product Series: 4000/6000 Fixed
Product Type: FIXD
Air Leakage:
VR (Standard Screen):
VR (Enhanced Screen):

Simulation Lab: SFTL
Sim. Report #: 9054-1
Sim. Report Date: 07/21/2016

Initial Cert. Date: 05/16/2007
Re-Certification Date: 08/26/2016
Revised Date: 12/13/2017

Print Date: 08/09/2018

Test Date: 07/14/2016

Expiration Date: 07/14/2021

CPD Number: LAW-A-4

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00066-00001	1/8 Comfort Select 36 - Arg - 1/8 Clear	AL/N	2	0.027(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.35	0.62	17
	00066-00002	1/8 Comfort Select 36 - Arg - 1/8 Clear	AL/N	2	0.027(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.35	0.62	17
	00066-00003	3/16 Comfort Select 36 - Arg - 3/16 Clear	AL/N	2	0.026(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.35	0.61	17
	00066-00004	3/16 Comfort Select 36 - Arg - 3/16 Clear	AL/N	2	0.026(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.35	0.61	17
	00067-00001	1/8 Clima Guard 55/27 - Arg - 1/8 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.52	17
	00067-00002	1/8 Clima Guard 55/27 - Arg - 1/8 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.52	17
	00067-00003	3/16 Clima Guard 55/27 - Arg - 3/16 Clear	AL/N	2	0.031(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.51	17
	00067-00004	3/16 Clima Guard 55/27 - Arg - 3/16 Clear	AL/N	2	0.031(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.28	0.51	17
	00068-00001	1/8 Clima Guard 63/31 - Arg - 1/8 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.31	0.58	17
	00068-00002	1/8 Clima Guard 63/31 - Arg - 1/8 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.31	0.58	17
	00068-00003	3/16 Clima Guard 63/31 - Arg - 3/16 Clear	AL/N	2	0.033(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.31	0.58	17
	00068-00004	3/16 Clima Guard 63/31 - Arg - 3/16 Clear	AL/N	2	0.033(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.31	0.58	17
	00069-00001	1/8 Clima Guard 70/36 - Arg - 1/8 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.33	0.59	17
	00069-00002	1/8 Clima Guard 70/36 - Arg - 1/8 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.33	0.59	17
	00069-00003	3/16 Clima Guard 70/36 - Arg - 3/16 Clear	AL/N	2	0.036(2)	0.250	A8-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.31	0.56	17
	00069-00004	3/16 Clima Guard 70/36 - Arg - 3/16 Clear	AL/N	2	0.036(2)	0.250	P1-S	Fill 1: ARG/AIR (90/10)	N		CL	0.46	0.31	0.56	17
	00070-00001	1/8 LoE 340 - Air - 1/8 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.53	0.20	0.36	17
	00070-00002	1/8 LoE 340 - Air - 1/8 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.53	0.20	0.36	17
	00070-00003	3/16 LoE 340 - Air - 3/16 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.53	0.20	0.35	17
	00070-00004	3/16 LoE 340 - Air - 3/16 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.53	0.20	0.35	17
	00071-00001	1/8 LoE 340 - Arg - 1/8 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.19	0.36	17
	00071-00002	1/8 LoE 340 - Arg - 1/8 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.19	0.36	17

NFRC Product Certification Authorization Report



Manufacturer: Lawson Industries
Street: 8501 NW 90th Street
City/State/Zip: Medley, FL 33166

Product Series: 4000/6000 Fixed
Product Type: FIXD
Air Leakage:
VR (Standard Screen):
VR (Enhanced Screen):

Simulation Lab: SFTL
Sim. Report #: 9054-1
Sim. Report Date: 07/21/2016

Initial Cert. Date: 05/16/2007
Re-Certification Date: 08/26/2016
Revised Date: 12/13/2017

Print Date: 08/09/2018

Test Date: 07/14/2016

Expiration Date: 07/14/2021

CPD Number: LAW-A-4

IA: American Architectural Manufacturers Association

Status	Product Num.	Manufacturer Code	Frame/Sash	Glaz Lyrs	Low-E (Surface)	Gap Width(s)	Spacer	Gap Fill	Grids	Dividers	Tint	U-Factor	SHGC	VT	Cond. Res.
	00071-00003	3/16 LoE 340 - Arg - 3/16 Clear	AL/AL	2	0.028(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.19	0.35	17
	00071-00004	3/16 LoE 340 - Arg - 3/16 Clear	AL/AL	2	0.028(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.19	0.35	17
	00072-00001	1/8 SunGuard 62/27 - Air - 1/8 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.53	0.28	0.58	17
	00072-00002	1/8 SunGuard 62/27 - Air - 1/8 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.53	0.28	0.58	17
	00072-00003	3/16 SunGuard 62/27 - Air - 3/16 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.53	0.28	0.57	17
	00072-00004	3/16 SunGuard 62/27 - Air - 3/16 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.53	0.28	0.57	17
	00073-00001	1/8 SunGuard 62/27 - Arg - 1/8 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.28	0.58	17
	00073-00002	1/8 SunGuard 62/27 - Arg - 1/8 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.28	0.58	17
	00073-00003	3/16 SunGuard 62/27 - Arg - 3/16 Clear	AL/AL	2	0.03(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.28	0.57	17
	00073-00004	3/16 SunGuard 62/27 - Arg - 3/16 Clear	AL/AL	2	0.03(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.46	0.28	0.57	17
	00074-00001	3/16 SunGuard Neutral 40 - Air - 3/16 Clear	AL/AL	2	0.149(2)	0.250	A8-S	Fill 1: AIR(100)	N		CL	0.55	0.32	0.38	19
	00074-00002	3/16 SunGuard Neutral 40 - Air - 3/16 Clear	AL/AL	2	0.149(2)	0.250	P1-S	Fill 1: AIR(100)	N		CL	0.55	0.32	0.38	19
	00075-00001	3/16 SunGuard Neutral 40 - Arg - 3/16 Clear	AL/AL	2	0.149(2)	0.250	A8-S	Fill 1: ARG/AIR(90/10)	N		CL	0.49	0.32	0.38	19
	00075-00002	3/16 SunGuard Neutral 40 - Arg - 3/16 Clear	AL/AL	2	0.149(2)	0.250	P1-S	Fill 1: ARG/AIR(90/10)	N		CL	0.49	0.32	0.38	19

Baseline Information

Test Lab	Test Date	Test Size	Tested U-Value	Standard U-Value	Test Report Number
TFTL	07/14/2016	1200 mm x 1500 mm	0.507	0.487	9012

Comments:

I hereby certify that all requirements for NFRC Certification Authorization have been met and that the above information is true and correct, to the best of my knowledge.

Authorized IA
Signature: _____